



Certificate

PROFIBUS Nutzerorganisation e.V. grants to

PR electronics A/S
Lerbakken 10; 8410 Ronde, Denmark

the Certificate No.: **Z00865** for the PROFIBUS Slave:

Product Name: PRetop 5350
Revision: 2.0; SW/FW: V2.03. PA01; HW: 53509004
GSD: PREL5350.gsd; Profile: PA139701.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Set_Slave_Add
<input checked="" type="checkbox"/>	DP-V1	MS2
<input type="checkbox"/>	DP-V2	
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.0
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: **055-02**
Authorized Test Laboratory: **ifak, Magdeburg, Germany**
Expiry date of Certificate: **November 30, 2009**


The tests were executed in accordance with the following documents:
"Test Specifications for Field Devices acc. to "PROFIBUS PA Profile for Process Control Devices, Version 3.0", Version 3.1".
This certificate is granted according to the document "Framework for testing and certification of PROFIBUS products".

Karlsruhe, February 08, 2007



.....
(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.



(K.-P. Lindner)



(Prof. K. Bender)